

UNIT NAME C-400-C Nickel Stripper Evaporation UnitREGULATORY STATUS RCRA Subtitle C facilityLOCATION C-400 Building (Map location 50)APPROXIMATE DIMENSIONS 100 gal tank; 4 fifty-five gal drumsFUNCTION Treatment unitOPERATIONAL STATUS ~~Active~~ Inactive ↓ closedDATES OPERATED 1986 to present

SITE/PROCESS DESCRIPTION: Currently, a stainless steel tank equipped with electric heaters is used. Prior to the installation of the tank, the evaporation took place in a steel drum equipped with a polyethylene liner.

WASTE DESCRIPTION: Nickel stripper waste solutionWASTE QUANTITY: 320-gal (permit max)

DESCRIPTION OF RELEASE:

DOCUMENTATION OF NO RELEASE: The unit has been operated in accordance with RCRA regulations. No major spills have occurred. Small leaks have been cleaned up as they occurred. The concrete floor of the building prevents the migration of any waste.

RFI NECESSARY: No