

UNIT NUMBER 87

UNIT NAME C-633 Pumphouse and Cooling Tower

REGULATORY STATUS CERCLA

LOCATION C-633 (Map location 87)

APPROXIMATE DIMENSIONS Wet well - 791,789
North basin - 4,045,767
South basin - 4,045,767

FUNCTION Pumping station and cooling tower for RCW system

OPERATIONAL STATUS ~~N/A~~ Active

DATES OPERATED 1951 to present

SITE/PROCESS DESCRIPTION: RCW from process buildings is cooled in induced-draft cooling towers. Wet wells at the base of the tower direct water to the pump station basins in the pumphouse.

WASTE DESCRIPTION: N/A

WASTE QUANTITY: Unknown

DESCRIPTION OF RELEASE: Chromated water may have leaked from concrete basins.

DOCUMENTATION OF NO RELEASE:

RFI NECESSARY: Yes