

UNIT NUMBER 88

UNIT NAME C-635 Pumhouse and Cooling Tower

REGULATORY STATUS CERCLA

LOCATION C-635 (Map location 88)

APPROXIMATE DIMENSIONS North basin - 1,769,648 gal  
South basin - 1,769,648 gal  
Wet well - 66,314

FUNCTION Pumping station and cooling tower for RCW system

OPERATIONAL STATUS ~~N/A~~ Active

DATES OPERATED 1953 to present

SITE/PROCESS DESCRIPTION: RCW from process buildings is cooled in induced-draft cooling towers. Wet wells at the base of the tower direct water to the pump station basins in the pumhouse.

WASTE DESCRIPTION: N/A

WASTE QUANTITY: Unknown

DESCRIPTION OF RELEASE: Chromated water may leak from the concrete basin

DOCUMENTATION OF NO RELEASE:

RFI NECESSARY: Yes