

**PRELIMINARY ASSESSMENT/SITE INSPECTION REPORT
AND SWMU ASSESSMENT REPORT**

UNIT NUMBER: 370

UNIT NAME: G-333-20

DATE: 01/19/2001

REGULATORY STATUS: SWMU

LOCATION: Column Sa 33

APPROXIMATE DIMENSION: 40 ft. X 20 ft.

FUNCTION: Generator Staging Area (GSA)

BRIEF HISTORY: According to USEC electrical maintenance personnel, this area was created to store process capacitors and associated equipment and miscellaneous materials that are PCB contaminated.

OPERATIONAL STATUS: Active

DATES OPERATED: According to USEC electrical maintenance personnel, this GSA has been operated from 1996 to present.

SITE/PROCESS DESCRIPTION: According to USEC electrical maintenance personnel, this diked storage area with plywood flooring and hypalon is used to store process capacitors containing PCB oil after removal from process cells and before shipment off-site. According to USEC electrical maintenance personnel, the storage area is managed in accordance with applicable regulations.

WASTE DESCRIPTION: PCB light ballasts, capacitors, PCB contaminated equipment.

WASTE QUANTITY: As of 12/12/00, this site contained one 55-gallon drum and one 30-gallon drum.

SUMMARY OF ENVIRONMENTAL SAMPLING DATA: None

DESCRIPTION OF RELEASE AND MEDIA AFFECTED: Based on interviews conducted with USEC electrical maintenance personnel, there have been no releases from this GSA, and no leaks within the GSA.

GROUNDWATER: N/A

SURFACE WATER: N/A

SOIL: N/A

ECOLOGY AFFECTED (i.e., endangered/threatened species): None

DOCUMENTATION OF NO RELEASE: According to USEC operations personnel, inspection sheets are on file documenting that there have been no releases from this SWMU.

IMPACT ON OR BY OTHER SWMU/AOC: SWMU 263 is approximately 20 ft. away. There is no evidence of any impact on or by it.

PRG COMPARISON: N/A

RFI NECESSARY: No. This unit is being proposed for No Further Action since this SWMU has had no releases to the environment and is not a threat to human health and the environment. According to USEC operations personnel, this unit has been managed and inspected in accordance with approved procedures since its creation.

NOTE: Elements included in this outline shall be considered and incorporated, as appropriate, when developing the above referenced document.