

**PRELIMINARY ASSESSMENT/SITE INSPECTION REPORT  
AND SWMU ASSESSMENT REPORT**

**UNIT NUMBER:** 389

**UNIT NAME:** G-533-01

**DATE:** 01/19/01

**REGULATORY STATUS:** SWMU

**LOCATION:** NE corner, ground floor.

**APPROXIMATE DIMENSION:** 5 ft. X 5 ft.

**FUNCTION:** Generator Staging Area (GSA)

**BRIEF HISTORY:** According to USEC Power Operations personnel, this GSA was established to store PCB contaminated waste generated during electrical maintenance activities.

**OPERATIONAL STATUS:** Active.

**DATES OPERATED:** 12/1/90 – present according to WESKEM, LLC GSA/SAA database

**SITE/PROCESS DESCRIPTION:** Storage for PCB contaminated waste. The waste is stored in drums. The waste in this GSA was generated from electrical maintenance activities.

**WASTE DESCRIPTION:** Oily rags, absorbent pigs, and gloves.

**WASTE QUANTITY:** One 55-gallon drum (<50 ppm PCB); one 55-gallon drum (>50 ppm PCB) as of 12/28/00. The waste quantity is not static since waste is routinely added to the storage area or into individual containers. In addition, waste containers are routinely removed from the area for off-site shipment or disposal.

**SUMMARY OF ENVIRONMENTAL SAMPLING DATA:** None

**DESCRIPTION OF RELEASE AND MEDIA AFFECTED:** According to USEC Power Operations personnel there have been no releases from this SWMU to the environment.

**GROUNDWATER:** N/A

**SURFACE WATER:** N/A

**SOIL:** N/A

**ECOLOGY AFFECTED (i.e., endangered/threatened species):** None

**DOCUMENTATION OF NO RELEASE:** According to USEC Power Operations and WESKEM, LLC personnel, inspection checklists are on file documenting that there have been no releases from this SWMU.

**IMPACT ON OR BY OTHER SWMU/AOC:** There were no other SWMUs identified in C-533 as of 12/28/00.

**PRG COMPARISON:** N/A

**RFI NECESSARY:** No. This unit is being proposed for No Further Action since building has had no releases to the environment, and is not a threat to human health and the environment. According to USEC Power Operations and WESKEM, LLC personnel, this unit has been managed and inspected in accordance with approved procedures since its creation.

**NOTE:** Elements included in this outline shall be considered and incorporated, as appropriate, when developing the above referenced document.