

**PRELIMINARY ASSESSMENT/SITE INSPECTION REPORT  
AND SWMU ASSESSMENT REPORT**

**UNIT NUMBER:** 390

**UNIT NAME:** G-535-02

**DATE:** 01/19/01

**REGULATORY STATUS:** SWMU

**LOCATION:** Parking lot, Southwest of C-535

**APPROXIMATE DIMENSION:** 15 ft. X 36 ft.

**FUNCTION:** Generator Staging Area (GSA)

**BRIEF HISTORY:** According to USEC Power Operations personnel, this area was designated as a temporary storage area for bushings removed from switchyard transformers.

**OPERATIONAL STATUS:** Inactive

**DATES OPERATED:** Approximately 3 weeks during 7/99.

**SITE/PROCESS DESCRIPTION:** Storage of electrical bushings containing PCBs that were removed from switchyard transformers in the electrical switchyards. The bushings were stored in wooden boxes.

**WASTE DESCRIPTION:** Electrical bushings containing PCBs.

**WASTE QUANTITY:** Empty as of January 2001, in the summer of 1999, there were 6 wooden boxes containing one bushing per box. Each box was 9 ft. X 2 ft. X 2.5 ft. This GSA was actively used to manage waste in accordance with BJC Company LLC Procedure No. PMWM-1007, "Waste Generator Responsibilities for On-Site Temporary Storage of Waste Materials," and applicable regulatory requirements.

**SUMMARY OF ENVIRONMENTAL SAMPLING DATA:** None

**DESCRIPTION OF RELEASE AND MEDIA AFFECTED:** According to USEC Power Operations personnel, there have been no releases from this SWMU to the environment.

**GROUNDWATER:** N/A

**SURFACE WATER:** N/A

**SOIL:** N/A

**ECOLOGY AFFECTED (i.e., endangered/threatened species):** None

**DOCUMENTATION OF NO RELEASE:** According to USEC Power Operations and WESKEM, LLC personnel, inspection checklists are on file documenting that there have been no releases from this SWMU.

**IMPACT ON OR BY OTHER SWMU/AOC:** There was no evidence of any impact on or by any other SWMU.

**PRG COMPARISON:** N/A

**RFI NECESSARY:** No. This unit is being proposed for No Further Action since it is located within a building has had no releases to the environment, and is not a threat to human health and the environment. According to USEC Power Operations and WESKEM, LLC personnel, this unit was managed and inspected in accordance with approved procedures during its operational history.

**NOTE:** Elements included in this outline shall be considered and incorporated, as appropriate, when developing the above referenced document.